

CERTIFICATE OF SUBSTANTIAL COMPLETION

DATE OF ISSUANCE May 20, 2010

OWNER St. Charles Parish
CONTRACTOR Sealevel Construction

Contract: _____
Project: Paradis Pump Station Bar Screen Cleaner and Deck

OWNER's Contract No. P070107 ENGINEER's Project No. 76491-00

This Certificate of Substantial Completion applies to all Work under the Contract Documents or to the following specified parts thereof:

All Work under the Contract Documents with the exception of task items noted in the attached punch list.

To St. Charles Parish _____
OWNER

And To Sealevel Construction _____
CONTRACTOR

The Work to which this Certificate applies has been inspected by authorized representatives of OWNER, CONTRACTOR and ENGINEER, and that Work is hereby declared to be substantially complete in accordance with the Contract Documents on

May 20, 2010
DATE OF SUBSTANTIAL COMPLETION

A tentative list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include an item in it does not alter the responsibility of CONTRACTOR to complete all the Work in accordance with the Contract Documents. The items in the tentative list shall be completed or corrected by CONTRACTOR within 7 days of the above date of Substantial Completion.

EJCDC No. 1910-8-D (1996 Edition)
Prepared by the Engineers' Joint Contract Documents Committee and endorsed by The Associated General Contractors of America and the Construction Specifications Institute.

The responsibilities between OWNER and CONTRACTOR for security, operation, safety, maintenance, heat, utilities, insurance and warranties and guarantees shall be as follows:

OWNER: _____

CONTRACTOR: _____

The following documents are attached to and made a part of this Certificate:
One (1) punch list indicating task items in need of completion.

[For items to be attached see definition of Substantial Completion as supplemented and other specifically noted conditions precedent to achieving Substantial Completion as required by Contract Documents.]

This certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of CONTRACTOR's obligation to complete the Work in accordance with the Contract Documents.


Executed by ENGINEER on May 20, 2010
Date

Buchart Horn, Inc
ENGINEER

By: 
(Authorized Signature)


CONTRACTOR accepts this Certificate of Substantial Completion on 5/31/10
Date

Sealevel Construction
CONTRACTOR

By: 
(Authorized Signature)

OWNER accepts this Certificate of Substantial Completion on 6/8/10
Date

St. Charles Parish
OWNER

By: 
(Authorized Signature)

RECORDED IN THE ST. CHARLES PARISH
CLERK OF COURT OFFICE

ON June 8, 2010

AS ENTRY NO. 361302

IN MORTGAGE/CONVEYANCE BOOK

NO. 1375 FOLIO 296



May 20, 2010

Buchart Horn, Inc.
Suite 502
9100 Bluebonnet Centre
Baton Rouge, LA 70809

(225) 293-1111
(800) 274-2224
Fax (225) 293-1116

Mr. Corbert Chaisson
Project Manager
Sealevel Construction
1069 Hwy 3185
Thibodaux, LA 70301

**RE: Paradis Pump Station Bar Screen Cleaner and Deck
St. Charles Parish - Project No. P070107
Final Construction Punch List**

York, PA
Coatesville, PA
Harrisburg, PA
Hershey, PA
King of Prussia, PA
New Cumberland, PA
Pittsburgh, PA
State College, PA
Stroudsburg, PA
Baltimore, MD
Marlton, NJ
Charleston, WV
Morgantown, WV
Memphis, TN
Baton Rouge, LA
Frankfurt/Main, Germany
Kaiserslautern, Germany

Dear Mr. Chaisson,

Items contained in this punch list were identified by representatives of St. Charles Parish and Buchart Horn, Inc during the Substantial Completion Inspection of the referenced project. All items on this punch list must be completed and/or corrected prior to acceptance of the contract. Items to be addressed are as follows:

1. General debris clean-up
2. Removal of coffer dam sheet piles
3. Dress out of back berm (maintaining existing height)
4. Completion of fence and personnel gate installation
5. Remove silt fencing except along south side of existing pump station fence. Only remove the plastic along that section.
6. Grade and level the entire area
7. Tighten anchor bolts on bar screen supports.

Regards,

Buchart-Horn, Inc

A handwritten signature in black ink, appearing to read 'Darius Bonton', is written over the printed name.

Darius Bonton, P.E.
Project Manager