

CERTIFICATE OF SUBSTANTIAL COMPLETION

DATE OF ISSUANCE July 7, 2014

OWNER St. Charles Parish Department of Waterworks
CONTRACTOR Hawkmoon Construction Services, LLC
Contract: LA 18 Cast Iron Replacement, Hahnville
Project: LA 18 Cast Iron Replacement, Hahnville

OWNER's Contract No. WWKS67

ENGINEER's Project No. N/A

This Certificate of Substantial Completion applies to all Work under the Contract Documents or to the following specified parts thereof:

A "new" waterline to replace the existing cast iron system from approximately Julia Street to Courthouse Lane, along LA 18 in Hahnville, LA.

To St. Charles Parish Department of Waterworks

OWNER

And To Hawkmoon Construction Services, LLC

CONTRACTOR

The Work to which this Certificate applies has been inspected by authorized representatives of OWNER, CONTRACTOR and ENGINEER, and that Work is hereby declared to be substantially complete in accordance with the Contract Documents on

6/13/14

DATE OF SUBSTANTIAL COMPLETION

A tentative list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include an item in it does not alter the responsibility of CONTRACTOR to complete all the Work in accordance with the Contract Documents. The items in the tentative list shall be completed or corrected by CONTRACTOR within 45 days of the above date of Substantial Completion.

The responsibilities between OWNER and CONTRACTOR for security, operation, safety, maintenance, heat, utilities, insurance and warranties and guarantees shall be as follows:

OWNER: Owner has full use and maintenance responsibility of the site.

CONTRACTOR: Complete the attached punch list within 45 days of substantial completion.

The following documents are attached to and made a part of this Certificate:

LA 18 Cast Iron Replacement, Hahnville Substantial Completion Punch List dated 6/26/14, items 1-20.

[For items to be attached see definition of Substantial Completion as supplemented and other specifically noted conditions precedent to achieving Substantial Completion as required by Contract Documents.]

This certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of CONTRACTOR's obligation to complete the Work in accordance with the Contract Documents. **Submit 6(six) original documents signed and dated by the engineer and contractor to Dept of Waterworks, 301 3rd Street, Luling, La 70070 for processing.**

Executed by ENGINEER on

7/17/14
Date

Danny J. Hebert, P.E., L.L.C.

ENGINEER

By:

(Authorized Signature)

CONTRACTOR accepts this Certificate of Substantial Completion on

7/7/2014
Date

Hawkmoon Construction Services, LLC

CONTRACTOR

By:

(Authorized Signature)

OWNER accepts this Certificate of Substantial Completion on

7-16-14
Date

St. Charles Parish Department of Waterworks

OWNER

By:

(Authorized Signature)

RECORDED IN THE ST. CHARLES PARISH
CLERK OF COURT OFFICE

ON 8/1/14

AS ENTRY NO. 399346

IN MORTGAGE/CONVEYANCE BOOK

NO. 1583 FOLIO 678



Civil & Environmental Consulting Engineers
 Danny J. Hebert, P.E., L.L.C.
 One American Place ~ 13919 River Road, Suite 310
 Luling, LA 70070
 www.hebertengineering.com
 phone: (985) 785-2380 fax: (985) 785-2388

PUNCH LIST
 ST. CHARLES PARISH
 LA 18 CAST IRON REPLACEMENT
 PROJECT No. WWKS67
 June 26, 2014

No.	Description
1	Center valve boxes to center of valve nut
2	Adjust Valve boxes to finish grade elevations
3	2' x 2' x 3 1/2" concrete pads to be poured around each valve
4	Cut a "V" shaped notch into roadway to indicate valve locations
5	Lay asphalt and concrete for road ways and driveways
6	Dress up areas where machinery made ruts
7	An electronic copy of as-built plans
8	Shape ditch banks and remove silt in ditch bottoms to insure proper drainage
9	Raise the last 3 fire hydrants that were installed from the Church property to Courthouse Ln. to 5" to 8" above finish grade
10	Repair LA 18 at Sta # 33+20 - sloughing to DOTD spec.
11	Correct erosion at the western corner of Keller St. culvert
12	Clean off all sidewalks free of dirt, sand, and rocks
13	Flow meter repair
14	Fix bent metal pole in driveway
15	Several low and high spots in ditches. Fill or excavate as required for proper drainage
16	Sweep driveways with rocks
17	Fix crack in LA 18 - patch with 4' wide pavement, 12" thick
18	Correct eroded rocks in culverts and driveways
19	Clean ditch and culvert at LA 3160
20	Place pavement at an angle by exposed valve on ditch bank