2023-0041

INTRODUCED BY: MATTHEW JEWELL, PARISH PRESIDENT (DEPARTMENT OF WASTEWATER)

RESOLUTION NO. 6686

A resolution notifying the Louisiana Department of Environmental Quality that the St. Charles Parish Department of Wastewater has reviewed the Municipal Water Pollution Prevention Environmental Audit Report for LA0073521 Al43357 - Hahnville Wastewater Treatment

Plant, and set forth the required action.

WHEREAS, the Louisiana Department of Environmental Quality Municipal Water Pollution Prevention Environmental Audit Report Program is designed to encourage municipal wastewater facilities to provide compliance maintenance prior to becoming noncompliant; and,

WHEREAS, it is necessary to submit the Environmental Audit to the Louisiana Department of Environmental Quality along with this resolution.

NOW, THEREFORE, BE IT RESOLVED, THAT WE, THE MEMBERS OF THE ST. CHARLES PARISH COUNCIL, do hereby notify the Louisiana Department of Environmental Quality that the St. Charles Parish Department of Wastewater has reviewed the Municipal Water Pollution Prevention Environmental Audit Report and sets forth the following action necessary to maintain permit requirements contained in The Hahnville WWTP's LPDES Permit:

- The Department has a Capacity, Management, Operation and Maintenance (CMOM) Program in place, which consists of a continuous program of monitoring, smoke testing and upgrading of existing sewer collection lines. The Department also uses its TV camera equipment to inspect the gravity lines in the system.
- b. The Department has a preventive maintenance program. This program consists of upgrading and rehabilitation of manholes, collection lines and lift stations including control panels.
- Domestic waste from the communities/areas of Hahnville, Taft, Killona, C. Paradis, Bayou Gauche, Des Allemands, Parts of Boutte, and Parts of Luling is treated through the Hahnville Wastewater Treatment Plant.
- d. In accordance with the conditions of the LDEQ State Revolving Loan Fund, the Wastewater Department will continue to repair manholes and sewer collection system lines that are old and dilapidated to prevent excessive inflow and infiltration causing overflows, bypasses and permit violations.

The foregoing resolution having been submitted to a vote, the vote thereon was as follows:

BILLINGS, FONSECA, DARENSBOURG GORDON, CLULEE, GIBBS, DUFRENE, BELLOCK, FISHER, FISHER-CORMIER YEAS:

NAYS: NONE ABSENT: NONE

And the resolution was declared adopted this <u>27th</u> day of <u>February</u>, 2023, to become effective five (5) days after publication in the Official Journal.

SECRETARY: \ DLVD/PARISH PRESIDENT: +ebruary APPROVED: DISAPPROVED PARISH PRESIDENT: RETD/SECRETARY: //ach AT: 9:21 am RECD BY:

LOUISIANA

MUNICIPAL WATER POLLUTION PREVENTION

MWPP



	St. Charles Parish Council
Facility Name:	Hahnville Wastewater
Ţ	Treatment Plant

LA 0073521

AI 43357 Agency Interest (AI) Number:

LPDES Permit Number:

Post Office Box 302 Address:

Hahnville, Louisiana 70057

St. Charles Parish:

Angela Troxler (Person Completing Form) Name:

> **Laboratory Coordinator** Title:

February 16, 2023 Date Completed:

PART 1: INELUENT FLOW/LOADINGS (altiplants)

A. List the average monthly volumetric flows and BOD loadings received at your facility during the last reporting year.

Column 1 Average Monthly Flow (million gallons per day, MGD)		Column 2 Average Monthly BOD5 Concentration (mg/l)		Column 3 Average Monthly BOD5 Loading (pounds per day, lb/day)
1.486	X	164	x 8.34 =	2,032
1.929	X	116	x 8.34 =	1,866
1.703	x	119	x 8.34 =	1,690
1.835	X	60	x 8.34 =	918
2.307	x	97	x 8.34 =	1,866
1.57	x	112	x 8.34 =	1,467
2.092	X	104	x 8.34 =	1,815
3.049	x	55	x 8.34 =	1,399
1.958	X	69	x 8.34 =	1,127
1.015	x	123	x 8.34 =	1,041
1.966	x	100	x 8.34 =	1,640
2.724	X	.130	x 8.34 =	2,953

BOD loading = Average Monthly Flow (in MGD) x Average Monthly BOD concentration (in mg/l) x 8.34

B. List the design flow and design BOD loading for your facility in the blanks below. If you are not aware of these design quantities, refer to your Operation and Maintenance (O&M) Manual or contact your consulting engineer.

Design Flow, MGD:	2.30	x 0.90 =	2.07
Design BOD, lb/day:	2,945	x 0.90 =	2,650.5

								Per	mit #:	L	4 007	3521		
C.	How m (WWT point to	F) ex	ceed 90	% of (design	flow?	Circle	the nu	ımber o	of mon	water ths and	treatme	ent faci orrespo	ility ding
	months	0	1	2	3	4	5	6	7	8	9	10	11	12
	points	0	0	0	0	0	5	5	5	5	5	5	5	5
						Write	0 or 5	in the	C poir	ıt total	box	0	C Poi	nt Total
D.	How m Circle to below a	the nu	ımber o	did the f mon	e mont ths and	hly flo	w (Col spondi	umn 1 ng poi) to the nt total.	WW7 Write	F exce e the p	eed the	design	n flow? ne box
	months	0	1	2	3	4	5	6	7	8	9	10	11	12
	points	0	5	5	10	10	15	15	15	15	15	15	15	15
					Write	0, 5, 10	0 or 15	in the	D poin	ıt total	box	10	D Poi	nt Total
E.	How most the control of the point	1esign	loadın	g? Ci	rcle the	e numb	er of n	ling (C nonths	Column and co	3) to t rrespo	he WV nding	WTF ex point t	ceed 9 otal. V	00% Vrite
	months	0	1	2	3	4	5	6	7	8	9	10	11	12
	points	0	0	5	5	5	10	10	10	10	10	10	10	10
					W	rite 0,	5,or 10	in the	E poin	it total	box	0	E Poir	ıt Total
F.	How m design point to	loadir	ıg? Cir	cle the	e numb	er of n	nonths	ling (C and co	Column orrespo	3) to t	he WV point t	VTF exotal. V	ceed the Vrite the	he ne
	months	0	1	2	3	4	5	6	7	8	9	10	11	12
	points	0	10	20	30	40	50	50	50	50	50	50	50	50
			W	rite 0,	10, 20	, 30, 4	0 or 50) in the	F poin	t total	box	10	F Poir	ıt Total
G.	Add to	gether	each p	oint to	otal for	C thro	ugh F	and pl	ace this	s sum i	n the b	oox bel	ow at t	he right.

Also enter this value or 80, whichever is less, on the point calculation table on page 16.

TOTAL POINT VALUE FOR PART 1: 20 (max = 80)

PART 2: BEEUENT QUALITY / PLANT PERFORMANCE

A. List the monthly average effluent BOD and TSS concentrations produced by your facility during the last reporting year.

Month	Column 1 Average Monthly BOD (mg/l)	Column 2 Average Monthly TSS (mg/l)
January 2022	3	4
February 2022	4	3
March 2022	4	2
April 2022	4	3
May 2022	2	2
June 2022	2	1
July 2022	2	2
August 2022	3	2
September 2022	2	1
October 2022	2	1
November 2022	2	1
December 2022	2	1

B. List the monthly average permit limits for your facility in the blanks below.

	Permit Limit	_	90% of Permit Limit
BOD, mg/l	30.0	x 0.90 =	27.0
TSS, mg/l	30.0	x 0.90 =	27.0

C. Continuous Discharge to Surface Water	C.	Continuous	Discharge t	to Surface	Water
--	----	------------	-------------	------------	-------

i.	How many months did the effluent BOD (Column 1) exceed 90% of the permit limits?
	Circle the number of months and the correspoding point total. Write the point total in
	the box below at the right.

monthspoints Write 0, 10, 20, 30 or 40 in the i point total box i Point Total

ii. How many months did the effluent BOD (Column 1) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

months points (0)Write 0, 5, or 10 in the ii point total box ii Point Total

iii. How many months did the effluent TSS (Column 2) exceed 90% of the permit limits? Circle the number of months and the correspoding point total. Write the point total in the box below at the right.

months points (0)

Write 0, 10, 20, 30 or 40 in the iii point total box 0 iii Point Total

iv. How many months did the effluent TSS (Column 2) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

months points

Write 0, 5, or 10 in the iv point total box 0 iv Point Total

v. Add together each point total for i through iv and place this sum in the box below at the right.

TOTAL POINT VALUE FOR PART 2: 0 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

	Permit #: LA 0073521
D.	Other Monitoring and Limitations
i.	At any time in the past year was there and exceedance of a permit limit for other pollutants such as: ammonia-nitrogen, phosphorus, pH, total residual chlorine, or fecal coliform?
	√ Check one box. Yes No If Yes, Please describe:
ii.	At any time in the past year was there a "failure" of a Biomonitoring (Whole Effluent Toxicity) test of the effluent?
	√ Check one box.
iii.	At any time in the past year was there an exceedance of a permit limit for a toxic
111.	substance?
	√ Check one box. Yes X No If Yes, Please describe:

PART'S: AGE OF THE WASTEWATER TREATMENT FACILITY.

A. What year was the wastewater treatment facility constructed or last major expansion/improvements completed?

 $\frac{2000}{Answer to A} = Age in very$

Current Year - Answer to A = Age in years $2022 \qquad 2000 \qquad 22$

Enter Age in Part C below.

B. $\sqrt{\text{Check}}$ the type of treatment facility that is employed.

X Mechanical Treatment Plant (trickling filter, activated sludge, etc...)
Specify Type: Activated Sludge

Aerated Lagoon 2.0
Stabilization Pond 1.5
Other
Specify Type: 1.0

C. Multiply the factor listed next to the type of facility your community employs by the age of your facility to determint the total point value for Part 3.

TOTAL POINT VALUE FOR PART 3 =

Also enter this value or 50, whichever is less, on the point calculation table on page 16.

D. Please attach a schematic of the treatment plant.

Permit	#

LA0073521

A. i.	List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to heavy rain:							
	1 V Check one box. $$ 0 = 0 points $$ 3 = 15 points $$ 4 = 30 points $$ 2 = 10 points $$ 5 or more = 50 points							
ii.	List the number of bypasses, overflows or unpermitted discharges shown in A (i) that were withing the collection system and the number at the treatement plant							
	Collection System: 1 Treatment Plant: 0							
B. i.	List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to equipment failure, either at the treatment plant or due to pumping problems in the collection system:							
	7 Check one box. $0 = 0$ points $3 = 15$ points $1 = 5$ points $4 = 30$ points $2 = 10$ points 5 or more $0 = 50$ points							
ii.	List the number of bypasses, overflows or unpermitted discharges shown in B (i) that were withing the collection system and the number at the treatement plant							
	Collection System: 7 Treatment Plant: 0							
C.	Specify whether the bypasses came from the city/village/town sewer system or from contract or tributary communities/sanitary districts, etc							
	City Sewer System							
D.	Add the point values checked for A and B and place the total in the box below.							
	TOTAL POINT VALUE FOR PART 4: 55 (max = 100) Also enter this value or 100, whichever is less, on the point calculation table on page 16.							
E.	List the person responsible (name and title) for reporting overflows, bypasses or unpermitted discharges to State and Federal authorities: David deGeneres, Assistant Director of Wastewater							
	Describe the procedure for gathering, compiling and reporting: Overflows, bypasses and unpermitted discharges are submitted by the operator and reported to the appropriate agencies (SPOC, DEQ and EPA).							

PARIES SEUDGE STORAGE AND DISPOSAL SHES

A. Sludge Storgage

How many months of sludge storage capacity does your facility have available, either on-site or off-site?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

months <2 2 3 4-5 points 50 30 20 10

Write 0, 10, 20, 30 or 40 in the A point total box 0 A Point Total

B. For how many months does your facility have access to (and approval for) sufficient land disposal sites to provide proper land disposal?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

months <2 6-11 12-23 24-35 36 points 50 30 20 10

Write 0, 10, 20, 30 or 40 in the B point total box 0 B Point Total

C. Add together the A and B point values and place the sum in the box below at the right:

TOTAL POINT VALUE FOR PART 5: 0 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

PAF	des Newden	ÆEØPM	ENI			
A.	Please provide the f were installed durin	following ing g the last ye	formation for ear.	the total	of all sewer line of	extensions which
	Design Population:	17	,000	_		
	Design Flow:		2.3	MGD		
	Design BOD:	30	0-45	mg/l		
В.	Has an industry (or in the past year, suc significantly increas	h that either	flow or pollu	ed into the tant load	e community or e ings to the sewer	expanded production age system were
	$\sqrt{\text{Check one box.}}$		Yes = 15 po	ints	X No = 0 poin	nts
	If Yes, Please descri	ibe:				
					·	
	List any new polluta None	ants:		***************************************		
C.	Is there any develop 2-3 years, such that significantly increas	either flow	strial, commer or pollutant lo	cial or re padings to	sidential) anticip the sewerage sy	ated in the next stem could
	$\sqrt{\text{Check one box.}}$		Yes = 15 po	ints	No = 0 poir	nts
	If Yes, Please descri	ibe:				
		,				
	List any new polluta None	ants you ant	icipate:		·	
				*1.	· · · · · · · · · · · · · · · · · · ·	
D.	Add together the po	int value ch	ecked in B an	d C and p	place the sum in t	he box below.
		TOT	TAL POINT	VALUE	FOR PART 6:	0 (max = 30)

Also enter this value or 30, whichever is less, on the point calculation table on page 16.

Permit #:

LA0073521

PART 7: OPERATOR CERTIFICATION AND EDUCATION

What was the name of the operator-in-charge for the reporting year?						
		Name:	······································	Travis Co	ortez	
.	What is his or her certif	ication number: Cert.#:		21-46	35	
•	What level of certificati wastewater treatment fa	on is the operator-in-c	harge required	arge required to have to operate the		
		Level Required:		IV	7.00	
) .	What is the level of cert	What is the level of certification of the operator-in-charge?				
		Level Certified:		IV	,	
t /•	Was the operator-in-char required in order to ope	Was the operator-in-charge of the report year certified at least at the grade level required in order to operate this plant?				
	\checkmark Check one box.	\overline{X} Yes = 0 point	ts	No =	= 50 points	
	Wri	te 0 or 50 in the E poir	nt total box	0 E Poi	nt Total	
•	Has the operator-in-chayear?	Has the operator-in-charge maintained recertification requirements during the reporting year?				
	√ Check one box.	X Yes		☐ No		
•	How many hours of corlast two calendar years?	How many hours of continuing education has the operator-in-charge completed over the last two calendar years?				
	\lor Check one box.	\boxed{X} > 12 hours =	0 points	<u> </u>	hours = 50 points	
	Writ	e 0 or 50 in the G poin	nt total box	0 G Po	int Total	
.•	Is there a written policy regarding continuing education an training for wastewater treatment plant employees?					
	√ Check one box.	X Yes		☐ No		
	<u> </u>	g is outlined in the es, Plant O&M Ma		-	_	
	What percentage of the paid for:					
	By the permittee?	100%	By the opera	ator?	0%	
	Add together the E and				ow at the right.	
		TOTAL POINT	VALUE FOR	PART 7:	$\boxed{0 \text{(max} = 100)}$	
	Also enter this value	or 100, whichever is 1				

Permit #:

LA0073521

PAF	UIS: FINANCIAL STATIUS - LE JULIET DE LA
A.	Are User-Charge Revenues sufficient to cover operation and maitenance expenses?
	√ Check one box. X Yes No If No, How are O&M costs financed?
	At present time the User-Charge Revenues are sufficient to cover operation and maintenance expenses.
В.	What financial resources do you have available to pay for your wastewater improvements and reconstruction needs?
	DEQ loans, grants, general fund and new ad valorem tax.

	SUBJECTIVE EVAPUATION	

A.	Collection	System	Maintenance
----	------------	--------	-------------

i. Describe what sewer system maintenance work has been done in the last year.

Clean and camera lines. Rehabilitate manholes. Repair broken lines. Locate and number manholes. GIS. Replaced force mains.

ii. Describe what lift station work has been done in the last year.

Pulled all pumps, inspected wet wells, control panels and all valves concerning lift stations and replace as necessary. New pumps and controls.

iii. What collection system improvements does the community have under construction for the next 5 years?

Upgrade lift stations, new force mains, and rehab gravity lines. SCADA and telemetry added to lift stations.

В.	If you have ponds please answer the following questions:	√ Check o	ne box.
i.	Do you have duckweed buildup in the ponds?	Yes	☐ No
ii.	Do you mow the dikes regularly (at least monthly), to the waters edge?	Yes	□ No
iii.	Do you have bushes or trees growing on the dikes or in		
iv.	the ponds? Do you have excess sludge buildup (> 1foot) on the bottom	Yes	∐ No
	of any of your ponds?	Yes	No
V.	Do you excersise all of your valves?	Yes	□ No
vi.	Are your control manholes in good structural shape?	Yes	No
vii.	Do you maintain at least 3 feet of freeboard in all of your	L	□ •••
	ponds?	Yes	☐ No
viii.	Do you visit your pond system at least weekly?	Yes	No

	Permit #:	LA0073521		
C.	Treatment Plants			
i.	Have the influent and effluent flow meters been calibrated in	n the last year?		
	Yes X No (√ Check one box.)			
ii.	Influent flow meter calibration date(s) Effluent flow meter calibration date(s) What problems, if any, have been experienced over the last year that have threatened treatment?			
	None			
iii.	Is your community presently involved in formal planning for treatment facility upgrade?			
	√ Check one box. Yes X No	f Yes, Please describe:		

	Permit #: LA0073521		
D.	Preventive Maintenance		
i.	Does your plant have a written plan for preventive maintenance on major equipment items?		
	√ Check one box. X Yes No If Yes, Please describe:		
	The Department's BMP as well as the manufactures manuals detailing PM and the Plant O&M Manual.		
ii.	Does this preventive maintenance program depict frequency of intervals, types of lubrication and other preventive maintenance tasks necessary for each piece of equipment? X Yes No		
iii.	Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assured properly?		
	X Yes No		
E.	Sewer Use Ordinance		
i.	Does your community have a sewer use ordinance that limits or prohibits the discharge of excessive conventional pollutants (BOD, TSS or pH) or toxic substances to the sewer system from industries, commercial users and residences?		
	√ Check one box. X Yes No If Yes, Please describe:		
	Ordinance 85-8-8 imposes BOD, TSS, pH, Oil and Grease, COD, and Metals limits on discharges. All limits correspond to average domestic strength domestic waste.		
ii.	Has it been necessary to enforce?		
	√ Check one box. X Yes No If Yes, Please describe:		
	We require all comercial and industrial users to abide by these limits.		
iii.	Any additional comments about your treatment plant or collection system? (Attach dditional sheets if necessary.)		

Permit #:

LA0073521

POINT CALCULATION TABLE

	Actual Values	Maximum
Part 1: Influent Flow/Loadings	20	80 points
Part 2: Effluent Quality / Plant Performance	0	100 points
Part 3: Age of WWTF	50	50 points
Part 4: Overflows and Bypasses	55	100 points
Part 5: Ultimate Disposition of Sludge	0	100 points
Part 6: New Development	0	30 points
Part 7: Operator Certification Training	0	100 points
TOTAL POINTS:	125	