CERTIFICATE OF SUBSTANTIAL COMPLETION

DATE OF ISSUANCE JULY 19, 2010

OWNER ST. CHARLES PARISH

CONTRACTOR BLD SERVICES LLC

Contract: P070108 SCHEXNAYDER AUTO BAR SCREEN

Project: SCHEXNAYDER BAR SCREEN CLEANER AND DECK

OWNER's Contract No. P070108

ENGINEER's Project No. 89207.B

This Certificate of Substantial Completion applies to all Work under the Contract Documents or to the following specified parts thereof:

PLEASE SEE ATTACHED PUNCHLIST

To <u>ST. CHARLES PARISH</u> OWNER

And To <u>BLD SERVICES LLC</u> CONTRACTOR

The Work to which this Certificate applies has been inspected by authorized representatives of OWNER, CONTRACTOR and ENGINEER, and that Work is hereby declared to be substantially complete in accordance with the Contract Documents on

JULY 19, 2010 DATE OF SUBSTANTIAL COMPLETION

A tentative list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include an item in it does not alter the responsibility of CONTRACTOR to complete all the Work in accordance with the Contract Documents. The items in the tentative list shall be completed or corrected by CONTRACTOR within 45 days of the above date of Substantial Completion.

EJCDC No. 1910-8-D (1996 Edition)
Prepared by the Engineers' Joint Contract Documents Committee and endorsed by The Associated General Contractors of America and the Construction Specifications
Institute.

The responsibilities between OWNER and CONTRACTOR for security, operation, safety, maintenance, heat, utilities, insurance and warranties and guarantees shall be as follows:
OWNER:
CONTRACTOR: 5 year warranty on the concrete approach slab
The following documents are attached to and made a part of this Certificate:
PUNCHLIST
This certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of CONTRACTOR's obligation to complete the Work in accordance with the Contract Documents. Submit 6(six) original documents signed and dated by the engineer and contractor to Dept of Public Works, 403 Milling Ave., Luling, La. 70070 for
processing.
Executed by ENGINEER on 7/19/10 SHREAD-KUYRKENDALL & ASSOCIATES, INC.
By: MULLA O DULL (Authorized Signature)
CONTRACTOR accepts this Certificate of Substantial Completion on 7/19/10
BLD SERVICES LLC CONTRACTOR
By: (Authorized Signature)
OWNER accepts this Certificate of Substantial Completion on 7/26/10
ST CHARLES PARISH OWNER
By: RECORDED IN THE ST. CHARLES PARISH (Authorized Signature) CLERK OF COURT OFFICE
ON July 27, 2010
AS ENTRY NO. 362560
I <u>N MORTGAG</u> E/CONVEYANCE BOOK NO. (381 FOLIO 775
00808_rev3

ST. CHARLES PARISH DEPARTMENT OF PUBLIC WORKS AND WASTERWATER

FINAL INSPECTION - PUNCHLIST

PROJECT NAME: St. Charles Parish Schexnayder Pump Station Bar Screen Cleaner

and Deck

PROJECT NUMBER: P070108

OWNER: St. Charles Parish CONTRACTOR: BLD Services, LLC

DATE: July 19, 2010 ENGINEER: Shread-Kuyrkendall & Assoc., Inc.

1. Electrical

a. Associated Pump shall be contacted to fix any electrical problems or concerns the Parish has questioned regarding the mechanical bar screen cleaners; more specifically the torque indicator on the small screen is not reading the correct number on the electrical panel. Associated Pump shall check and confirm that all torque indicators in the electrical panel are working in compliance with the manufacturers specifications. Contractor shall contact the Parish Electrician prior to completing these repairs.

2. Deck

- a. The area between the new concrete deck and the existing deck needs to be covered by using an aluminum deck plate or equivalent.
- b. The fence post on the side of the small screen needs to have a cap placed on the top of the post.

3. Mechanical Bar Screens

- a. Add 2 grease fittings to the small bar screen cleaner
- b. Fillers need to be placed on the sides of the sheet pile and the bar screen cleaner. Location was determined in the field.
- c. The fingers shall be replaced on the large bar screen cleaners.