



**CONTRACT DOCUMENTS
FOR
KINLER AND PAUL FREDRICK ROADWAY AND
DRAINAGE IMPROVEMENTS PHASE I
PROJECT NO. P210704**

ADDENDUM NO. 2

DATE ISSUED: MAY 28, 2026

**BID OPEN DATE: JUNE 2, 2026 AT 10:00 AM
BID OPEN LOCATION: St. Charles Parish Courthouse
15045 River Road, 2nd Floor, Hahnville Louisiana, 70057**

This addendum shall be part of the contract documents as provided in the Instructions to Bidders.

The following items are issued to add to, modify, and clarify the Contract Documents. These items shall have full force and effect as the Contract Documents, and the cost involved shall be included in the bid prices.

Acknowledge receipt of the addendum by inserting its number on the Bid Form of the Bid Documents. Failure to do so will subject the bidder to rejection.

The Addendum No. 2 consists of 2 pages including all attachments.

I. CONTRACTORS' QUESTIONS

- The deadline for questions on this project was May 26, 2026, by C.O.B.

Q: Can local available river sand be used as a type b backfill material for drain pipe backfill for this project?

A: Yes.

Q: Will the 96" tree and stump have to be removed in B-3 servitude?

A: Yes.

Q: Will pre-cast headwalls be considered for this this project if available?

A: Yes.

Q: Will laydown area be available on lot 37-kinler st. i saw that sewer contractor was using that lot for parking or laydown?

A: **Lay down is between property owner and contractor. Parish does not own lot #37.**

Q: Is there an engineer's estimate?

A: **Answered in Addendum No. 1.**