



The following documents are attached to and made part of this Certificate:

4/26/2013 Punch List Memorandum from Grant Walsh to Robert Brou, SCP Director of Water Works

This Certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of Contractor's obligation to complete the Work in accordance with the Contract Documents.

 Executed by Engineer	4/26/13 Date
 Accepted by Contractor	4/26/13 Date
 Accepted by Owner	4/11/13 Date

UNOFFICIAL

**St. Charles Parish
Department Of Waterworks**

To: Robby Brou

From: Grant Walsh

Subject: C Plant Punch List

Date: 4/26/13

1. Finish bolting down deck plates.
2. Finish putting toe plate on hand rail.
3. Put supports on two outside covers that are falling inside clarifier.
4. Pour cement around bottom of clarifier.
5. Change out a few screws on launder covers to stainless.
6. Install missing piece of hand rail on the outside of C-Plant clearwell.
7. Mount #7 service pump emergency stop controls that were cut off old hand rails.
8. Get proper size handle for C-Plants dump valve
9. General clean up.
10. Install pipe stands under concentrators.
11. Insulate concentrators.

If you have any questions please contact me at 783-5116

Grant Walsh

UNOFFICIAL