


Industrial & Mechanical Contractors, Inc.

• P.O. BOX 10008 • 757 CENTRAL AVENUE •
• JEFFERSON, LOUISIANA 70181 •
• (504) 733-6266 FAX (504) 733-9144 •

August 22, 2017

Mr. Larry Cochran
St. Charles Parish
P.O. Box 302
Hahnville, LA 70057



Re: Mimosa Park Drainage Improvements
St. Charles Parish Project No. P0900904

Dear Mr. Cochran:

Reference is made to your letter dated August 14, 2017 regarding the possibility of placing IMC in default.

IMC has an obligation to bring the above to the owner's attention, which we have on several occasions without a reply from the owner or engineer.

Simply put, if we excavate and replace pipe with the same pipe that was specified and approved, it will again fail unless different methods of backfilling are used. The alternate backfill method is not specified and this would be an additional cost.


We have three alternatives:

1. Replace pipe as per specifications.
The manufacturer will not provide a warranty if the pipe is replaced in the manner as the contract documents and the pipe will fail again.
2. Replace pipe using sand backfill in lieu of native soil.
3. Replace pipe using sand and shoring.

Alternatives No.2 and No.3 would be extra costs.

Once again, please instruct us as to what method should be employed so we can get this job completed. We are available at your convenience to discuss.

Sincerely,


Harold Heidingsfelder President

cc: Mr. Clayton Faucheux Public Works Director
Mr. Ryan Martiny Travelers Casualty & Surety Company of America
Mr. David Vicknair Esq. Attorney
Mr. Todd Phillip E&T Construction

