

SECTION 00805

WORK CHANGE DIRECTIVE

No. 3

DATE OF ISSUANCE July 16, 2026 EFFECTIVE DATE July 23, 2026

Owner: St. Charles Parish

Contractor: Sealevel Construction, Inc.

Contract: Ordinance No. 25-4-13; Montz Pump Station No. 1; Date 4/23/2025

Project: Montz Pump Station No. 1

Owner's Contract No.: P210301 Engineer's Contract No.: 39145-1312

ENGINEER: GIS Engineering, LLC

Contractor is directed to proceed promptly with the following change(s):

Description:

1. Relocation of the bar screen LCPs from two on each end of the wall to between each screen to accommodate the E-Stops and jog controls. This change results in no change to the contract cost.
2. Reroute the electrical conduits for the bar screen LCPs behind the 5-foot screen wall, between the wall and the bar screens. This change results in no change to the contract cost.

Attachments: (List documents supporting change):

Purpose for Work Change Directive:

Directive to proceed promptly with the Work described herein, prior to agreeing to changes on Contract Price and Contract Time, is issued due to: *(check one)*

- ☐ Non-agreement on pricing of proposed change.
☒ Necessity to proceed for schedule or other project reasons.


Estimated Change in Contract Price and Contract Times (non-binding, preliminary):

Contract Price: \$ 0 [increase] **[decrease]**

Contract Time: 0 days [increase] [decrease]

Basis of estimated change in Contract Price:

- ☐ Lump Sum ☒ Unit Price
☐ Cost of the Work ☐ Other

Recommended:  Limited Authorization By*:  Received: 
By: Agustin Rega, PE By: Sam Scholle By:
Engineer (Authorized Signature) Owner's Representative* Contractor (Authorized Signature)
Title: Project Manager Title: *Jovee Projects Manager* Title: President
Date: 07/16/2026 Date: *8-6-2026* Date: 8/4/2026

*Owner's Representative is not authorized to finalize a Change Order nor does the Work Change Directive substitute the Change Order process as more fully set out in the General Conditions of the Construction Contract.

Approved by Funding Agency (if applicable)

By: _____ Date: _____
Title: _____